


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 494

Date: 21/10/2017

It is certified that an inspection team headed by the Authorized Officer of Public Health Department Visited the premises of The Vedaant International School, ChhotaBangarda Road, District Indore on 30/09/2017 and As per the sample found that the school The Vedaant International School, ChhotaBangarda, Air port Road, District Indore has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Govt.


Signature with Seal 

Name : M.K. KHARE

Designation : Asst. Engr.

(Engineer Public Health) Assistant Engineer
Maintenance Sub-Division No. 5
Indore Municipal Corporation, Indore

To
The Vedaant International School,
ChhotaBangarda Road, Near Airport Police Station
District - Indore (M.P.)
(Name & Address of the Institution)


Manager
The Vedansh International School
INDORE (M.P.)


Principal
The Vedansh International School
Indore

Water Testing Laboratory

Indore Municipal Corporation, Musakhedi, Indore

Email:- Amritindore@gmail.com, waterlabimc@outlook.com, Phone No.: 0731-2712842

71
NO:/QM/IMC/M/2023-24/Indore

Date 11-07-23

To, *The Principal*
Vednash International School
Indore (M.P.)

Subject: . Test Report of Water samples.

Reference: Your letter No. - Date 03-07-23.


Please find enclosed herewith report of water samples/invoice/Money receipt of sample/samples received for analysis as per the letter under reference.


Enclosures: As above

Quality Manager
Water testing Laboratory
Musakhedi, IMC, Indore

Copy to: Chief Executive Office (Laboratory), Maintenance Div. No. 2 I.M.C. information please.
Enclosures: As above

Quality Manager
Water testing Laboratory
Musakhedi, IMC, Indore


The Vedansh International School
INDORE (M.P.)


Principal
The Vedansh International School
Indore


Water Testing Laboratory
Maintenance Division No. 2, Narmada Project
I.M.C. Indore M.P.

"C"

01-03-07-23 Rep No. 473574

S.No.	Detail Of Sample	Date of collection	Location	Dt. of Commencement				
	To,		Indore (M.P.)					
	The Principal		i) R.O					
	Vednash International School.		ii) Boring.					
			I	II				
S.No.	Tests	Units	Desirable Limit	Permissible Limit	Result 1	Result 2	Result 3	Result 4
1	Temperature	°C	-	-	-	-		
✓2	Colour	Pt.Co.Scale	5	25	Low	Low		
✓3	Odour		Agreeable	Agreeable	A9	A9		
✓4	Turbidity	N.T.U.	1	25	0.54	0.33		
✓5	pH	pH Scale	6.5-8.5	No Relaxation	7.11	7.42		
✓6	Alkalinity	mg/l	200	600	116	240		
✓7	Total Hardness	mg/l	300	600	136	452.4		
✓8	Chloride	mg/l	250	1000	18	176		
✓9	Fluoride	mg/l	1	1.5	0.26	0.38		
✓10	Iron	mg/l	0.3	No Relaxation	BDL	BDL		
11	Calcium	mg/l	75	200	-	-		
	Sodium	mg/l	30	100	-	-		
				400	-	-		


Manager
 The Vedansh International School
 INDORE (M.P.)


 Principal
 The Vedansh International School
 Indore

Water Testing Laboratory
Indore Municipal corporation, Musakhedi,
Indore (M.P.)

Date _____

Proforma Invoice

To, *The Principal*
Vedansh International School
Ref. :- Personal visit *Indore*

S.no.	Test	# Rate Per Test		Rate applica- ble	Number of test	Amount INR
		For Public & Govt. Concern	For Commercial Concern			
✓1	Color	100	250	250	1 No.	250=00
2	Odour test	100	250	250		
✓3	Turbidity	100	250	250	"	250=00
✓4	pH	100	250	250	2 Nos.	500=00
✓5	Alkalinity	100	250	250	1 No.	250=00
✓6	Total Hardness	150	375	375	1 No.	375=00.
7	Calcium	150	250	250		
8	Magnesium	80	200	200		
✓9	Chloride	100	250	250	1 No.	250=00
✓10	Ammonia	100	250	250	2 No.	500=00.
11	Nitrite	100	250	250		
✓12	Nitrate	100	250	250	1 No.	250=00
13	Sulphite test	150	375	375		
14	B.O.D. test	150	375	375		
15	C.O.D. test	150	375	375		
16	Phosphate test	150	375	375		
✓17	Sulphate	150	375	375	1 No.	375=00.
18	Dissolved Solution	150	375	375		
19	Total Solid test	150	375	375		
20	Dissolved Oxygen test	150	375	375		
✓21	Total Coli form (MPN)	200	500	500	2 No.	1000=00.
22	Bleaching Powder/hypo	100	250	250		
23	Residual Chlorine	150	250	250		
✓24	Fluoride	150	250	250	1 No.	250=00
✓25	Iron	150	250	250	1 No.	250=00.
Total =	One thousand Eight Hundred Fifty only Four Thousand Five Hundred only					

*Rate applicable w.e.f. 30/5/96 as per letter 2029/TS munit. Div. No 2 Indore dated 10/06/1996

1. There will be no refund of money of to customer if laboratory unavailable to performed test in case of failure of instrument/equipment or any other reasons. Only credit noted will be issue to customer. Credit note can remitted by us in future test.
2. You can't submit/published Test certificated or its part as evidence in court matter/ paper / e-media without written permission form this office.
3. Payments are accepted either cash , by cheque /D.D./ NIFT/RTGE payable in favor of Cossimminor M C Indore. A/c No. 53003150303 State bank of India Corporation branch Indore IFSC code SBIN0030134

copy to CEO WTL Musakhedi Indore for approval please

QUALITY MANAGER
WATER TESTING LABORATORY
INDORE MUNICIPAL CORPORATION

[Signature]
Manager

The Vedansh International School
INDORE (M.P.)

[Signature]
Principal

The Vedansh International School
Indore

"C"

Water Testing Laboratory
Maintenance Division No. 2, Narmada Project
I.M.C. Indore M.P.

01-03-07-23 Rep No. 473 & 74

S.No.	Detail Of Sample	Date of collection	Location	Dt of Commencement				
	To, The Principal Vednash International School.		Indore (M.P.) i) R.O ii) Boring.					
S.No.	Tests	Units	Desirable Limit	Permissible Limit	Result 1	Result 2	Result 3	Result 4
1	Temperature	°C	-	25	Low	Low		
✓2	Colour	Pt.Co.Scale	Agreeable	Agreeable	Ag	Ag		
✓3	Odour		1	25	0.54	0.33		
✓4	Turbidity	N.T.U.	6.5-8.5	No Relaxation	7.11	7.42		
✓5	pH	pH Scale			116	240		
✓6	Alkalinity	mg/l	200	600	136	452.4		
✓7	Total Hardness	mg/l	300	600	18	176		
✓8	Chloride	mg/l	250	1000	0.26	0.38		
✓9	Fluoride	mg/l	1	1.5	BDL	BDL		
✓10	Iron	mg/l	0.3	No Relaxation	-	-		
11	Calcium	mg/l	75	200	-	-		
12	Magnesium	mg/l	30	100	-	-		
13	Sulphate	mg/l	200	400	BDL	8.5		
✓14	Nitrate	mg/l	45	No Relaxation	113	598		
✓15	Total Dissolved Solids EC	mg/l	500	2000	-	-		
16	Residual chlorine	mg/l	0.2	1	ND	ND		
✓17	Fecal Coliform	CFU 100ml	ND	ND	0.20	0.54		

18) Ammonia

CHEMIST

ND → Not Detected.

Manager

The Vedansh International School
INDORE (M.P.)

(Signature)
Technical Manager
Water Testing Laboratory
I.M.C. Indore

Principal

The Vedansh International School
Indore

AE. Maint. Sub-Dn. 8
IMC Indore